

Asbury Theological Seminary

ePLACE: preserving, learning, and creative exchange

Subject Files

Indian Springs Camp Meeting

2021

Box 1-86 (Subject File, Buildings & Grounds-Updates, 1999-2008)

ATS Special Collections and Archives

Follow this and additional works at: <https://place.asburyseminary.edu/indianspringscmssubjectfiles>



Part of the [Christianity Commons](#)

Indian Springs Holiness
Campground
Buildings and Grounds

August 31, 2006

August Update 2006

I am sending this by mail, the computer (modem) has not arrived, and the company is working to fix the problem.

We did not have a July Update most everything was in preparation for camp. This has been a busy month shutting down after camp last month. We have had a few gully washers which have made everything very green and muddy.

Equipment; *we replaced the CASE transmission and Hydraulic filters.
Repaired the Bucket truck control handle.

Water/Sewer; **Replaced water meters on Cottage #203 Stumbo, #202 Monette, and #45 Peed. * Repaired back up in sewer line in lot#20 * Repaired water leak in 1/2" waterline in front of Youth Taber. *Water started the month at 400 gph. Over the last week we have been as low as 50 gph. *Sewer has been our biggest project of the month. The 8" main that runs below Pond road behind Glenn Taber. blew out during camp. In locating the cause we rented a Rotor-Rooter and had to brake open the pipe 7 additional places. We have repaired 5,.. 2 remain along with the original brake. In our search an additional 4" line was found blocked/broken which we repaired.*

Grounds; **We finished the lot prep (#211) for the trailer that was brought in by Rabun Smith. [waterline, meter, sewer, retaining rocks, dig for electric and electric pole, grass seed and straw]*

Buildings; **We have turned off the water and drained the pipes to 18 of our buildings. This was not winterizing, in November we will see how many have evaporated and antifreeze those that haven't. *We have replaced the vesqueen in the green house with plastic panels. *We put up the leaf tarp around the Main Tabernacle. *Glazed two windows in the Mathews Memorial. [Note; all the windows need to be re-glazed, primed and painted]*

We will be looking into the water leak under the cafeteria's kitchen floor. We are hoping to only have two holes in the concrete,.. Hoping!

That's about all from here. If anyone has any thoughts, comments or suggestions, let me know.

IGWT,
Wink

1971

... ..

... ..

... ..

... ..

... ..

... ..

... ..

... ..

... ..

... ..

... ..

... ..

... ..

... ..

... ..

Middlebrook